



**MCI CONSTRUCTORS, INC.**

2000 Pennsylvania Avenue, N.W.  
Washington, D.C. 20006  
Attn: General Services Administration  
Telephone: (202) 456-1234  
Teletype: (202) 456-1234  
Fax: (202) 456-1234

August 28, 1985

General Services Administration  
New Building Project Office, Room 3E40  
CIA Headquarters Building  
Washington, DC 20505

Ltr. #28-171

Attention: Mr. Arthur Carlucci  
Contracting Officer's Authorized Representative  
Reference: Contract #GS-11B-19067  
Subject: Telephone Service Outage, C.O.R. #98-8

Dear Arthur,

On August 26th at approximately 9 a.m., we experienced an unscheduled telephone service outage. Following inspection by C&P Telephone, it was determined that the problem was not in the lines put in by them. After further review and investigation, we found the problem to be that the telephone lines had been cut by the CIA grounds maintenance crew. This obviously occurred during the mowing of the area east of the motorpool and south of the security trailers.

At no time did the grounds maintenance crew attempt to discover what and/or whose lines were cut, even though the damage was more than apparent.

We were able to make the appropriate repairs on August 27th, after the damage was discovered. This incident left us without telephone service for approximately 24 hours.

We will be submitting a bill to your Agency to cover all expenses incurred during this time and for any repairs that have been made to correct the damage.

Should you have any question, please feel free to contact me.

Sincerely,

MCI CONSTRUCTORS, INC.

*Matina D. Kelly*  
Matina D. Kelly

cc: WFJ



M/O, Job #28

STAT